



## TEST REPORT No. MVZ-A-2021-001951

Customer:

Object of the test:

**PVC FLOORING**

Date: 2021-10-07

Number of pages: 2

Number of annexes: 0

Copies: 2 Copy No. 1: Customer  
Copy No. 2: MVZ archive

Copy No: 1

The results of tests contained in this Test Protocol apply only to the tested subject, as was received, and the Test Protocol does not mean approval of the product by the body granting accreditation or by any other body. The testing laboratory is not responsible for the information supplied by the customer. Customer data is marked in italics in the protocol. The tests outside the extent of accreditation and sub-contracted are designated. The ČIA accreditation does not apply to the results of tests titled „Outside the extent of accreditation“.

The Protocol shall not be copied otherwise but as a whole, and to use its part or section you need the written consent of the testing laboratory.

Original copies have relief stamp.

In case of misunderstanding, the Czech version is valid.



Ing. Anna Součková  
head of the Material and product testing department

## 1. OBJECT AND PURPOSE OF THE TEST:

The purpose of the test is the determination of the formaldehyde release of the supplied sample of PVC Flooring.

## 2. TEST SAMPLES:

Sample codes (laboratory): sample No. 278  
Sample name: PVC Flooring  
Sample description: PVC Flooring  
Producer:

Quantity, size: 3 pieces, (600 x 190) mm  
Nominal thickness: 8 mm  
Date of production: unknown  
Date of reception: September 27. 2021  
Place of reception: VVÚD - MVZ  
Received: VVÚD; Šárka Podlenová  
Handed down: by post

## 3. TEST METHOD:

- TP-VVÚD-2.64.001 (ČSN EN 717-1) - Determination of formaldehyde in test chamber of VVÚD.

Testing conditions for TP-VVÚD-2.64.001 (ČSN EN 717-1):  
Volume of the chamber 0,225 m<sup>3</sup>  
determination of emission value by the acetylacetone method

## 4. DATE OF THE TEST:

4 to 6 October 2021

## 5. TEST RESULTS:

Sample No. 278

chamber value 0,001 mg HCHO/m<sup>3</sup> of air

This test report made by: Petra Volfová

- End of report -

